



JON J. P. FERNANDEZ
Superintendent of Education

**DEPARTMENT OF EDUCATION
OFFICE OF SUPPLY MANAGEMENT**

www.gdoe.net
501 Mariner Avenue
B-Building, Suite 116
Barrigada, Guam 96913
Telephone: (671) 475-0438/Fax: (671) 472-5001
Email: procurement@gdoe.net



CARMEN T. CHARFAUROS
Supply Management Administrator

AMENDMENT ACKNOWLEDGEMENT FORM

IFB 005-2021

**Walkway Canopy Replacement for H.B. Price Elementary School
AMENDMENT 2**

December 22, 2020

Please review the attached document (All Notice/Amendments can be reviewed on our website). Please sign this acknowledgement page and only return this page, attention to **KATHRINA O. BAYSON** via email to kobayson@gdoe.net.

I, _____, an authorized representative of the company named below, acknowledge receipt of **AMENDMENT 2**, for **IFB 005-2021 Walkway Canopy Replacement for H.B. Price Elementary School**. Number of pages: 3 (including this coversheet).

Company Name (Print)

Print Name

Signature

Time and Date



JON J. P. FERNANDEZ
Superintendent of Education

DEPARTMENT OF EDUCATION
OFFICE OF SUPPLY MANAGEMENT

www.gdoe.net
501 Mariner Avenue
B-Building, Suite 116
Barrigada, Guam 96913
Telephone: (671) 475-0438/Fax: (671) 472-5001
Email: procurement@gdoe.net



CARMEN T. CHARFAUROS
Supply Management Administrator

December 22, 2020

AMENDMENT 2

Prospective Bidders:

Please refer to our **Invitation for Bid No. 005-2021 Walkway Canopy Replacement for H.B. Price Elementary School**, a copy of which was obtained by your company for consideration.

GDOE is hereby making the following changes to the IFB:

EXHIBIT A – Design Drawings

1. Replace Sheet T-1 with **Revised Sheet T-1A**
2. Replace Sheet D-3 with **Revised Sheet D-3A**
3. Replace Sheet A-1 with **Revised Sheet A-1A**
4. Replace Sheet A-2 with **Revised Sheet A-2A**
5. Replace Sheet S-1 with **Revised Sheet S-1A**
6. Replace Sheet S-2 with **Revised Sheet S-2A**
7. Replace Sheet S-3 with **Revised Sheet S-3A**
8. Insert **New Sheet S-3.1A**
9. Replace Sheet S-4 with **Revised Sheet S-4A**
10. Replace Sheet S-5 with **Revised Sheet S-5A**

All design drawings referenced above is available **VIA DOWNLOAD LINK ONLY AT:**

<http://bit.ly/IFB-005-2021-Amendment-2-Design-Drawings>

Please see below questions submitted by Prospective Bidder(s):

Valcon Guam, LLC

1. As of right now, Valcon does not have bonding in-place. Would it still be possible for us to proceed in joining the bidding for the project/s?

GDOE Response: Bid Bond is required. Please refer to page 8 of the IFB, Section 3.1.16.1.

J&B Modern Tech

1. As per Section A/D-3, 3" PVC Pipe to remain, whereas on New Roof Plan 2/A-3 Call out # 2, Provide 2" PVC Sch 40 Downspout with 3 ea Galvanized Strap Typical.

GDOE Response: See Sheet D-3A in this amendment for revised PVC pipe diameter. Sheet A-3 remains unchanged.

2. The existing Post Pipe diameter is 4-1/2" whereas on Section detail 1,2, & 3/S-4 shows Existing 3" Pipe Post to remain.

GDOE Response: See Sheet S-4A in this amendment. Pipe post diameters in Building Section Detail 1/S-4, 2/S-4 and 3/S-4 have been revised.

3. As per Section 1/S-1, Joint connection on existing pipe were flush to existing pipe, If new pipe to be used is 3-1/2" pipe diameter and the existing is 4-1/2" the joint connection will not be flushed.

GDOE Response: See Sheet S-1A in this amendment. Diameter of new pipe has been revised.

4. As per Section Detail 4/S-5, Steel Plate dimension is 5"x5"x1/4" whereas on Plan Detail 5/S-5 shows 4"x4"x1/4". Please advise on which dimension are we going to use?


GDOE Response: See Sheet S-5A in this amendment. Steel plate dimension on Plan Detail 5/S-5 has been revised.

5. On Detail 7/S-5, Please provide detail dimension on concrete stopper along the edge of the roof.

GDOE Response: See Sheet S-5A in this amendment. Detail dimensions on concrete stopper are provided.

All else remains the same.

Sincerely,


CARMEN T. CHARFAUROS
Supply Management Administrator