



JON J. P. FERNANDEZ
Superintendent of Education

DEPARTMENT OF EDUCATION
OFFICE OF SUPPLY MANAGEMENT
www.gdoe.net
501 Mariner Avenue
B-Building, Suite 116
Barrigada, Guam 96913
Telephone: (671) 475-0438/Fax: (671) 472-5001
Email: procurement@gdoe.net



CARMEN T. CHARFAUROS
Supply Management Administrator

AMENDMENT ACKNOWLEDGEMENT FORM

IFB 031-2021
Typhoon Shutters for Various Public Schools
AMENDMENT 1

June 15, 2021

Please review the attached document (All Notice/Amendments can be reviewed on our website). Please sign this acknowledgement page and only return this page, attention to **KATHRINA O. BAYSON** via fax (671) 472-5001 or via email to kobayson@gdoe.net.

I, _____, an authorized representative of the company named below, acknowledge receipt of **AMENDMENT 1**, for **IFB 031-2021 Typhoon Shutters for Various Public Schools**. Number of pages: **3** (including this coversheet).

Company Name (Print)

Print Name

Signature

Time and Date



JON J. P. FERNANDEZ
Superintendent of Education

DEPARTMENT OF EDUCATION
OFFICE OF SUPPLY MANAGEMENT
www.gdoe.net
501 Mariner Avenue
B-Building, Suite 116
Barrigada, Guam 96913
Telephone: (671) 475-0438/Fax: (671) 472-5001
Email: procurement@gdoe.net



CARMEN T. CHARFAUROS
Supply Management Administrator

June 15, 2021

AMENDMENT 1

Prospective Bidders:

Please refer to our **Invitation for Bid No. 031-2021 Typhoon Shutters for Various Public Schools**, a copy of which was obtained by your company for consideration.

GDOE is hereby making the following changes to the IFB:

Page 5, Section 2.3 – PROJECT DESCRIPTION

From: 5. Project completion of ninety (90) calendar days upon issuance of Notice to Proceed.

To: 5. Project completion of sixty (60) calendar days upon issuance of Notice to Proceed.

Page 11, Section 3.2.4 – DURATION OF AWARD

From: The duration of this award shall be ninety (90) calendar days after the issuance of the Notice to Proceed, subject to the availability of funds and subject to the terms of this IFB and to the terms of the contract agreement.

To: The duration of this award shall be sixty (60) calendar days after the issuance of the Notice to Proceed, subject to the availability of funds and subject to the terms of this IFB and to the terms of the contract agreement.

Page 12, Section 3.2.8 – DELIVERY OF GOODS

From: The project shall be completed within Ninety (90) calendar days after the issuance of the Notice to Proceed (NTP).

To: The project shall be completed within Sixty (60) calendar days after the issuance of the Notice to Proceed (NTP).

Please see below responses to questions submitted by Prospective Bidder(s):

JJ Global Services

1. Will you be able to send me the listing of who registered just to make sure before I move forward?

GDOE Response: The following vendors have registered for the Bid: (1) Premier International Inc. dba Carpet Masters, (2) JJ Global Services, (3) USA Contractors Inc., (4) WBH LLC, (5) Liang Corporation, (6) JMI Edison, (7) Tridon Corporation, (8) JC Marketing, Inc., and (9) Pacific Federal Management.

Carpet Master & Shutter Factory

2. As per the specs, it is indicated that the shutter must meet American Society for Testing & Materials (ASTM) standard. Is this a federally funded project?

GDOE Response: Yes. Please refer to page 12 of the IFB, Section 3.2.7.

3. Does the product need to meet the "Buy America Act" (Made in USA)?

GDOE Response: No. It does not need to meet the "Buy America Act".

4. If the shutter must meet the ASTM Standards, the shutter must be tested by a US Lab for Static Air Pressure and the Wind load Rating of 170MPH sustain wind speed. Please clarify.

GDOE Response: Yes. It must meet ASTM Standards.

5. The standard color for the electrostatic applied paint is White and Bronze. The Specified Hi-Tech brand also comes in White and Bronze only. Please clarify the acceptable color.

GDOE Response: White.

WBH LLC

6. What does it mean by rough openings on the typhoon shutters? Can you please provide a picture of exactly the type of shutters GDOE is looking for?

GDOE Response: Rough opening is the existing opening. Photo is not available. Please follow scope of work and requirements on Section 2.3 and Attachment A of the IFB.

7. For 1.02 Submittals Section B, what does GDOE mean by showing shop drawings? Do you want us to submit a design of how we are going to install it? Can you please explain more exactly what will need to be done here?

GDOE Response: Yes. Upon award, winning bidder shall provide shop drawings showing layout, sizes and types, product materials, components and accessories, fabrication data, finishes, rough-in dimensions, anchorage and installation requirements and details.

8. For 1.03 Section C, is pre installation conference only done when the vendor is chosen in the end to do the project before installation?

GDOE Response: Yes.

9. For Section 2.01, "Provide (Hi-Tech)(Bernardo) shutter system", is that a specific kind of shutter you are looking? Can you please elaborate "(Hi-Tech)(Bernardo)"?

GDOE Response: Bernardo is a recommended brand, however it is not required. Substantially equivalent products will be considered for award. Please refer to Section 3.2.19 of the IFB. Typhoon shutters must be rated at 170 MPH as identified in Ch16 Section 1609 of the 2009 International Building Code.

10. Is there a specific brand of typhoon shutters GDOE is looking for?

GDOE Response: Bernardo is a recommended brand, however it is not required. Substantially equivalent products will be considered for award. Please refer to Section 3.2.19 of the IFB. Typhoon shutters must be rated at 170 MPH as identified in Ch16 Section 1609 of the 2009 International Building Code.

11. When will the job be done? During school hours or only during weekends?

GDOE Response: After school hours and weekends.

All else remains the same.

Sincerely,


CARMEN T. CHARFAUROS
Supply Management Administrator