



JON J. P. FERNANDEZ  
Superintendent of Education

DEPARTMENT OF EDUCATION  
OFFICE OF SUPPLY MANAGEMENT  
[www.gdoe.net](http://www.gdoe.net)  
501 Mariner Avenue  
B-Building, Suite 116  
Barrigada, Guam 96913  
Telephone: (671) 475-0438/Fax: (671) 472-5001  
Email: [procurement@gdoe.net](mailto:procurement@gdoe.net)



CARMEN T. CHARFAUROS  
Supply Management Administrator

**AMENDMENT ACKNOWLEDGEMENT FORM**

**IFB 032-2021**

**Electrical Repairs and Upgrades for George Washington High School and H.B. Price Elementary School**  
**AMENDMENT 2**

July 19, 2021

Please review the attached document (All Notice/Amendments can be reviewed on our website). Please sign this acknowledgement page and only return this page, attention to **KATHRINA O. BAYSON** via email to [kobayson@gdoe.net](mailto:kobayson@gdoe.net).

I, \_\_\_\_\_, an authorized representative of the company named below, acknowledge receipt of **AMENDMENT 2**, for **IFB 032-2021 Electrical Repairs and Upgrades for George Washington High School and H.B. Price Elementary School**. Number of pages: 3 (including this coversheet).

\_\_\_\_\_  
**Company Name (Print)**

\_\_\_\_\_  
**Print Name**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Time and Date**



DEPARTMENT OF EDUCATION  
OFFICE OF SUPPLY MANAGEMENT

[www.gdoe.net](http://www.gdoe.net)

501 Mariner Avenue

B-Building, Suite 116

Barrigada, Guam 96913

Telephone: (671) 475-0438/Fax: (671) 472-5001

Email: [procurement@gdoe.net](mailto:procurement@gdoe.net)

JON J. P. FERNANDEZ  
Superintendent of Education



CARMEN T. CHARFAUROS  
Supply Management Administrator

July 19, 2021

**AMENDMENT 2**

**Prospective Bidders:**

Please refer to our **Invitation for Bid No. 032-2021 Electrical Repairs and Upgrades for George Washington High School and H.B. Price Elementary School**, a copy of which was obtained by your company for consideration.

GDOE is hereby making the following changes to the IFB:

**Page 3, Section 1.1 – INVITATION FOR BID (IFB) TIMELINE**

From:

<u>DATE</u>	<u>ACTIVITY</u>	<u>TIME</u>
Friday, July 23, 2021	Deadline for Submission and Bid Opening	10:00 a.m. Chamorro Standard Time (ChST)
Friday, July 23, 2021	Public Bid Opening (via video conference)	10:30 a.m. Chamorro Standard Time (ChST)

To:

<u>DATE</u>	<u>ACTIVITY</u>	<u>TIME</u>
Tuesday, August 03, 2021	Deadline for Submission and Bid Opening	10:00 a.m. Chamorro Standard Time (ChST)
Tuesday, August 03, 2021	Public Bid Opening (via video conference)	10:30 a.m. Chamorro Standard Time (ChST)

**Page 6, Section 3.1.4 – TIME AND DATE FOR RECEIPT OF BIDS**

From: Bids must be received by GDOE no later than:  
TIME: 10:00 a.m. Chamorro Standard Time (ChST)  
DATE: Friday, July 23, 2021

To: Bids must be received by GDOE no later than:  
TIME: 10:00 a.m. Chamorro Standard Time (ChST)  
DATE: Tuesday, August 3, 2021

**Page 6, Section 3.1.4 – TIME AND DATE FOR RECEIPT OF BIDS**

*Curb-side drop off schedule*

From: Due to the current COVID-19 pandemic, proper safety protocols must be adhered to. If the bid submission will be hand-delivered, delivery will be conducted via CURB-SIDE DROP OFF from Monday, July 19, 2021 through Tuesday, July 20, 2021, 8:30 a.m. to 3:00 p.m., Thursday, July 22, 2021, 8:30 a.m. to 3:00 p.m., and Friday, July 23, 2021, 8:30 a.m. to 9:45 a.m. (15 minute intervals).

**To:** Due to the current COVID-19 pandemic, proper safety protocols must be adhered to. If the bid submission will be hand-delivered, delivery will be conducted via CURB-SIDE DROP OFF from Wednesday, July 28, 2021 through Friday, July 30, 2021, 8:30 a.m. to 3:00 p.m., Monday, August 2, 2021, 8:30 a.m. to 3:00 p.m., and Tuesday, August 3, 2021, 8:30 a.m. to 9:45 a.m. (15 minute intervals).

**Page 7, Section 3.1.5 – RECEIPT AND OPENING OF BIDS**

**From:** In order to adhere to social distancing requirements, bids shall be opened publicly via video conference on the time and date specified below:

TIME: 10:30 a.m. Chamorro Standard Time (CHST)

DATE: Friday, July 23, 2021

**To:** In order to adhere to social distancing requirements, bids shall be opened publicly via video conference on the time and date specified below:

TIME: 10:30 a.m. Chamorro Standard Time (CHST)

DATE: Tuesday, August 3, 2021

GDOE has received the following questions and has deemed it in the best interest of the Department to respond to the questions. See below questions submitted by Prospective Bidder:

**SET Electric Inc.**

For GWHS:

1. As shown on the SLD there are 4 Junction Boxes - where is the JB's located

***GDOE Response: Intercept and install within the electrical room as shown on accessible location.***

2. After the JB's it goes to existing loads, are the conduits and cables going to existing loads included in the bid?

***GDOE Response: No. Circuit(s) are to be intercepted as indicated. Conduits and cables to remain from new junction box to existing loads.***

3. Also, the cable and conduit sizes going to the JB's are not indicated.

***GDOE Response: Cable and conduit sizes to match existing.***

4. Cable sizes for control circuit from Load Shed Panel to ATS is not indicated.

***GDOE Response: Cables sizes for Load shed panel are per manufacturer's recommendation.***

All else remains the same.

Sincerely,

  
CARMEN T. CHARFAUROS  
Supply Management Administrator